

Ref: 1566781



October 2019

To Whom It May Concern

**Compliance with the Health Act 1956 and the Drinking-water Standards for New Zealand
for the period 1st July 2018 – 30th June 2019**

Summary of DWSNZ Compliance

Full compliance with the DWSNZ and the Act for the 2018-2019 compliance year was achieved for

- Gisborne City supply

Partial compliance with DWSNZ and the Act for the 2018-2019 compliance year was achieved for

- Te Karaka supply
- Whatatutu supply

Treatment Plants

Plant name	Bacterial Compliance	Protozoa Compliance	Cyanotoxin Compliance	Chemical Compliance	Radiological Compliance	Overall Compliance
Waingake	✓	✓	✓	✓	N/A	✓
Waipaoa	✓	✓	✓	N/A	N/A	✓
Te Karaka	✓	✗	✓	N/A	✓	✓
Whatatutu	✓	✗	✓	N/A	✓	✓

Distribution Zones

Distribution zone name	Bacterial Compliance	Cyanotoxin Compliance	Chemical Compliance	Overall Compliance
Gisborne City	✓	N/A	✓	✓
Gisborne Rural	✓	N/A	✓	✓
Te Karaka	✓	N/A	N/A	✓
Whatatutu	✓	N/A	N/A	✓

Compliance with Duties in the Act

Section of the Act	Compliance	
69S: Duty of suppliers in relation to the provision of drinking water	x	Achieved for Gisborne City supply and Whatatutu supply Not achieved for Te Karaka supply
69U: Duty to take reasonable steps to contribute to protection of source of drinking water	✓	Achieved for all supplies
69Z: Duty to prepare and implement a Water Safety Plan (WSP)	✓	Achieved for all supplies
69ZD: Duty to keep records and make them available	✓	Achieved for all supplies
69ZE: Duty to investigate complaints	✓	Achieved for all supplies

Queries can be referred to Service@gdc.govt.nz

Yours sincerely



Judith Robertson

Team Leader Drinking water