

23 September 2021

To whom it may concern

Compliance with the Health Act 1956 and the Drinking-water Standards for New Zealand

1 July 2020 – 30 June 2021

This summary replaces the summary dated 22 September 2021.

Results from compliance assessments carried out on the Gisborne District Council drinking water supplies for the period 01 July 2020 – 30 June 2021 are summarized below:

Summary of Compliance with Duties of Drinking Water Suppliers under the Act

Section of the Act	Compliance	
69S: Duty of suppliers in relation to the provision of drinking water	✓	Achieved for all supplies
69U: Duty to take reasonable steps to contribute to protection of source of drinking water	✓	Achieved for all supplies
69Z: Duty to prepare and implement a Water Safety Plan (WSP)	✓	Achieved for all supplies
69ZD: Duty to keep records and make them available	✓	Achieved for all supplies
69ZE: Duty to investigate complaints	✓	Achieved for all supplies
69ZF: Duty to take remedial actions if drinking-water standards are breached	✓	Achieved for all supplies

Summary of Compliance with DWSNZ

Full compliance with the DWSNZ and the Act for the 2020- 2021 compliance year was achieved for

- Gisborne City supply

Partial compliance with the DWSNZ and the Act for the 2019-2020 compliance year was achieved for

- Te Karaka supply
- Whatatutu supply

Treatment Plants

Plant name	Bacterial Compliance	Protozoa Compliance	Cyanotoxin Compliance	Chemical Compliance	Overall Compliance
Waingake	✓	✓	✓	✓	✓
Waipaoa	✓	✓	✓	N/A	✓
Te Karaka	✓	✗	✓	N/A	✓
Whatatutu	✓	✗	✓	N/A	?

Distribution Zones

Distribution zone name	Bacterial Compliance	Cyanotoxin Compliance	Chemical Compliance	Overall Compliance
Gisborne City	✓	N/A	✓	✓
Gisborne Rural	✓	N/A	✓	✓
Te Karaka	✓	N/A	N/A	✓
Whatatutu	✓	N/A	N/A	✓

Yours sincerely,



Cathy Walker
Drinking Water
Assessor Hauora
Tairāwhiti