



## Drinking Water Supplied to Gisborne City

### Monitoring Results and Compliance Status – 1 July 2023 to 31 December 2023

#### Microbiological Compliance:

Determinand	Drinking Water Standards for NZ requirements	GDC Monitoring	Results	Compliance
<i>E. coli</i>	Less than 1 in 100mL of sample	Via grab samples	34 samples all less than 1	Yes
Total pathogenic protozoa	Less than 1 verified infectious (oo)cyst per 100mL of sample	Via various treatment plant processes	Met continuous monitoring limits	Yes

#### Chemical Compliance:

Determinand	Drinking Water Standards for NZ requirements	GDC Monitoring	Results	Compliance
Inorganic determinands	Less than Maximum Acceptable Value (MAV <sup>1</sup> )	To meet DWQAR <sup>2</sup>	All results less than MAV	Yes
organic determinands	Less than Maximum Acceptable Value (MAV)	To meet DWQAR	All results less than MAV	Yes

Further details are available on request.

<sup>1</sup> Available on the Taumata Arowai website [New Standards, Rules, and Aesthetic Values | Taumata Arowai](#).

<sup>2</sup> DWQAR are the Drinking Water Quality Assurance Rules website available on the Taumata Arowai website [New Standards, Rules, and Aesthetic Values | Taumata Arowai](#).